

Potable Water Testing Results
Mott Community College
January 19, 2016

Potable water testing for lead was done on January 19, 2016 at all hydration station locations and at showers in Ballenger Field House and Durham Wellness and Physical Education Center. Samples were collected by MCC's Physical Plant personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.

pB = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected

EPA maximum allowable level for lead = 15 ppb.

MCC cautionary level = 5 ppb, at which time remedial action will be taken.

* These units have two bubblers but only one water source. All water runs through the same filter, requiring only one sample.

Location	Sample ID	1/19/2016 pB Result ppb	Response
Ballenger Field House			
Hydration Stations			
Men's Locker Room	BFH_HS 1-1	ND	
Hallway to Men's Locker Room	BFH_HS 1-2	ND	
Main Entry, South Side	BFH_HS 1-3	ND	
Main Entry, North Side	BFH_HS 1-4	ND	
Hallway to Women's Locker Room	BFH_HS 1-5	ND	
Women's Locker Room	BFH_HS 1-6	ND	
Showers			
Men's Shower Room	BFH_SHWR 1-1	ND	
Athletic Director	BFH_SHWR 1-2	ND	
Assistant Athletic Director	BFH_SHWR 1-3	22	Every Monday - Flush for one hour, monitor
Women's Shower Room	BFH_SHWR 1-4	34	Every Monday - Flush for one hour, monitor
Curtice Mott Complex			
Hydration Stations			
Administration Hallway by 1019	CM_HS 1-1	ND	
1st Flr, West Hallway by 1104	CM_HS 1-2	ND	
1st Flr, West Hallway by 1112	CM_HS 1-3	ND	
1st Flr, West Hallway by 1120	CM_HS 1-4	ND	
1st Flr, East Hallway by 1132	CM_HS 1-5	ND	
1st Flr, East Hallway by 1146	CM_HS 1-6	ND	
1st Flr, North East Hallway by Vending	CM_HS 1-7	ND	
1st Flr, South East Hallway by 1307	CM_HS 1-8	ND	

Potable Water Testing Results
Mott Community College
January 19, 2016

2nd Flr, South West Hallway by 2001	CM_HS 2-1	ND	
2nd Flr, South West Hallway by 2018	CM_HS 2-2	ND	
2nd Flr, South West Hallway by 2033	CM_HS 2-3	ND	
2nd Flr, West Hallway by 2118	CM_HS 2-4	ND	
2nd Flr, East Hallway by 2138	CM_HS 2-5	ND	
2nd Flr, East Hallway by Vending	CM_HS 2-6	ND	

Durham Wellness and Physical Education Center

Hydration Stations

* Main Floor South, Strength/Cardio	DP_HS 1-1	ND	
* Main Floor North, Functional 1 & 2	DP_HS 1-2	3	Unit piped incorrectly. Corrected; filter changed; Retest

Showers

Men's Shower Room	DP_SHWR 1-1	40	Every Monday - Flush for one hour
Women's Shower Room	DP_SHWR 1-2	16	Every Monday - Flush for one hour

Gorman Science Center

Hydration Stations

1st Flr, Left Unit (while facing)	G_HS 1-1	ND	
1st Flr, Center Unit	G_HS 1-2	ND	
1st Flr, Right Unit (while facing)	G_HS 1-3	ND	
2nd Flr, Left Unit (while facing)	G_HS 2-1	ND	
2nd Flr, Center Unit	G_HS 2-2	ND	
2nd Flr, Right Unit (while facing)	G_HS 2-3	ND	
3rd Flr, Left Unit (while facing)	G_HS 3-1	ND	
3rd Flr, Center Unit	G_HS 3-2	ND	
3rd Flr, Right Unit (while facing)	G_HS 3-3	ND	

Mott Library

Hydration Stations

* 1st Floor by 1016	ML_HS 1-1	ND	
* 1st Floor Events Center	ML_HS 1-2	ND	
* 2nd Floor by Elevator	ML_HS 2-1	ND	
* 2nd Floor by 2202	ML_HS 2-2	ND	
* 3rd Floor by 3003	ML_HS 3-1	ND	
* 3rd Floor by 3202	ML_HS 3-2	ND	

Mott Memorial Building

Hydration Stations

Terrace Level, Media Services	MMB_HS SB-1	ND	
1st Floor by 1127	MMB_HS 1-1	ND	
1st Floor Main Entrance	MMB_HS 1-2	ND	

Potable Water Testing Results
Mott Community College
January 19, 2016

1st Floor by 1025	MMB_HS 1-3	ND
1st Floor Music Wing	MMB_HS 1-4	ND
2nd Floor by 2129	MMB_HS 2-1	ND
2nd Floor by 2002	MMB_HS 2-2	ND
2nd Floor by 2011	MMB_HS 2-3	ND
2nd Floor by 2019	MMB_HS 2-4	ND
2nd Floor Dental Wing	MMB_HS 2-5	ND

Prahl College Center

Hydration Stations

* Lower Level	PCC_HS B-1	ND
* 1st Floor Information Desk	PCC_HS 1-1	ND
* 2nd Floor	PCC_HS 2-1	ND

Public Safety

Hydration Stations

Vehicle Bay	PS_HS 1-1	ND
Administrative Hallway	PS_HS 2-1	1 Change Filter, Retest

Regional Technology Center

Hydrations Stations

* 1st Floor by 1201	RTC_HS 1-1	ND
* 1st Floor by 1404	RTC_HS 1-2	ND
* 1st Floor by 1009	RTC_HS 1-3	ND
* 2nd Floor by 2201	RTC_HS 2-1	ND
* 2nd Floor by 2404	RTC_HS 2-2	ND
* 3rd Floor by 3201	RTC_HS 3-1	ND
* 3rd Floor by 3604	RTC_HS 3-2	ND

Visual Arts and Design Center

Hydration Stations

North Hallway by Vending	VADC_HS 1-1	ND
South Hallway between restrooms, Left	VADC_HS 1-2	ND
South Hallway between restrooms, Right	VADC_HS 1-3	ND
South Hallway by 1118B	VADC_HS 1-4	ND

Wagner Workforce Education Center

Hydration Stations

1st Floor Information Desk	WAG_HS 1-1	ND
2nd Floor by Restrooms	WAG_HS 2-1	ND