

Potable water testing for lead was done on, February 9, 2017 at the following drinking fountains, and sinks at Mott Community College site locations. A retest was conducted of Lapeer staff breakroom sink on February 20, 2017. The retest consisted of two (2) samples, one from the filter and one directly from the tap. Samples were collected by MCC's Risk Management personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.

pb = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected

EPA maximum allowable level for lead - 15 ppb

MCC cautionary level for potable water = 5 ppb, at which time remedial action will be taken

OOO - Out of Order

Location	Sample ID	2/20/2017	2/20/2017	2/9/2017	Response
		Retest	Retest		
Lapeer					
Drinking Fountains					
Large Commons, C320	LAPR_DF 1-1			4	
Small Commons, MiWorks!	LAPR_DF 1-2			ND	
Sinks					
Staff Breakroom, LAPR C314	LAPR_FS 1-1	ND	1	25	Filter installed immediately, Retested
LAPR C317	LAPR_S 1-2			3	
Staff Kitchenette, LAPR B206	LAPR_S 1-3			1	
Continuing Education, B218	LAPR_S 1-4			2	
Michigan Works!, A101	LAPR_S 1-5			1	
Northern Tier Center					
Drinking Fountains					
Commons, Drinking Fountain 1 (Left)	NTC_DF 1-1			ND	
Commons, Drinking Fountain 2 (Right)	NTC_DF 1-2			ND	
Sinks					
Main Office Kitchenette, NTC 105	NTC_S 1-1			ND	
Servery, NTC 113A	NTC_S 1-2			3	
Great Lakes Baptist					
Sinks					
Kitchenette	GLBC_FS 1-1			ND	

Hispanic Community Center

Sink			
Kitchen	HTC_FS 1-1		ND

Disability Network

Hydration Stations			
Main Entry	DN_HS 1-1		ND
Sink			
Kitchenette	DN_FS 1-1		ND

Southern Lakes Branch Campus

Drinking Fountains			
Hallway by 1104, West entry	SLB_DF 1-1		ND
Within 1104	SLB_DF 1-2		OOS
Hallway by 1004 (Davenport0	SLB_DF 1-3		2
Hallway by 1304	SLB_DF 1-4		ND
Hallway by 1104, East Entry	SLB_DF 1-5		4
Academy Fountain, building C	SLC_DF 1-1		ND
Sinks			
Staff Breakroom, 1104A	SLB_FS 1-1		ND
PTA/OTA 1012, Kitchenette	SLB_S 1-2		ND
PTA/OTA 1016	SLB_S 1-3		2
PTA/OTA 1502	SLB_FS 1-4		ND

Livingston MTEC

Hydration Stations			
Hallway by Restrooms, Left unit	LIV_DF 1-1		ND
Hallway by Restrooms, Right unit	LIV_DF 1-2		ND
Highbay, Left Unit	LIV_DF 1-3		ND
Highbay, Right Unit	LIV_DF 1-4		ND
Sinks			
Staff Kitchenette	LIV_S 1-1		ND
Certified Aide Classroom 105, Left sink	LIV_S 1-2		ND
Certified Aide Classroom 105, Right sink	LIV_S 1-3		ND