

Potable water testing for lead was done on, September 19, 2017 at all hydrations station locations, filtered sinks, and ice machines at Mott Community College. Showers were also tested at Ballenger Field House and Durham Wellness and Physical Education Center. Samples were collected by MCC's Risk Management personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.

**pb** = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected

EPA maximum allowable level for lead - 15 ppb

MCC cautionary level for potable water = 5 ppb, at which time remedial action will be taken

\* These units have two bubblers but only one water source. All water runs through the same filter, requiring only one sample

\*\* Name Change - Sample ID's previously started with "D"

OOO - Out of Order

Location	Sample ID	10/2/2017	9/19/2017	Response
<b>Ballenger Field House</b>				
Hydration Stations				
Men's Locker Room	BFH_HS 1-1		ND	
Hallway to Men's Locker Room	BFH_HS 1-2		ND	
Main Entry, South Side	BFH_HS 1-3		ND	
Main Entry, North Side	BFH_HS 1-4		1	
Hallway to Women's Locker Room	BFH_HS 1-5		ND	
Sinks				
Athletic Concessions, RM 122	BFH_FS 1-1		ND	
Women's Hospitality Room, RM 1208	BFH_FS 1-2		ND	
Ice Makers				
Athletics Concessions, RM 122	BFH_IM 1-1		ND	
Showers				
Men's Shower Room	BFH_SHWR 1-1		ND	
Athletic Director	BFH_SHWR 1-2		ND	
Unisex Shower, RM 1204	BFH_SHWR 1-3		ND	
Unisex Shower, RM 1206	BFH_SHWR 1-4		ND	
Lady Bear Shower RM 1410A, Stall 1 (ADA)	BFH_SHWR 1-5.1		ND	
Lady Bear Shower RM 1410A, Stall 2	BFH_SHWR 1-5.2	ND	58	Non potable. Flush, Retest
Lady Bear Shower RM 1410A, Stall 3	BFH_SHWR 1-5.3		ND	
Visiting Woman's Shower RM 1804A, Stall 1 (ADA)	BFH_SHWR 1-6.1		ND	
visiting Woman's Shower RM 1804A, Stall 2	BFH_SHWR 1-6.2		ND	
visiting Woman's Shower RM 1804A, Stall 3	BFH_SHWR 1-6.3		ND	

Location	Sample ID	10/2/2017	9/19/2017	Response
<b>Curtrice Mott Complex</b>				
Hydration Stations				
Administration Hallway by 1019	CM_HS 1-1		1	
1st Flr, West Hallway by 1104	CM_HS 1-2		2	
1st Flr, West Hallway by 1112	CM_HS 1-3		ND	
1st Flr, West Hallway by 1120	CM_HS 1-4		ND	
1st Flr, East Hallway by 1132	CM_HS 1-5		ND	
1st Flr, East Hallway by 1146	CM_HS 1-6		ND	
1st Flr, North East Hallway by Vending	CM_HS 1-7		ND	
1st Flr, South East Hallway by 1307	CM_HS 1-8		ND	
2nd Flr, South West Hallway by 2001	CM_HS 2-1		ND	
2nd Flr, South West Hallway by 2018	CM_HS 2-2		ND	
2nd Flr, South West Hallway by 2033	CM_HS 2-3		ND	
2nd Flr, West Hallway by 2118	CM_HS 2-4		ND	
2nd Flr, East Hallway by 2138	CM_HS 2-5		ND	
2nd Flr, East Hallway by Vending	CM_HS 2-6		ND	
Sinks				
Admin Staff Lounge, CM 1004	CM_FS 1-1		ND	
Presidential Coffee Bar, CM 1019	CM_FS 1-2		1	
Staff Lounge, CM 1113	CM_FS 1-3		ND	
Custodial Lounge	CM_FS 1-4		ND	
Emergency Operations Center, CM 1143	CM_FS 1-5		ND	
PS Health & Medical Services, CM 1146A	CM_FS 1-6		ND	
Computer Support Services Breakroom, CM 1208H	CM_FS 1-7		ND	
Printing/Shipping & Receiving Kitchen, CM 1309J	CM_FS 1-8		ND	
E-Learning Office, CM 2124	CM_FS 2-1		ND	
Business Division, CM 2133E	CM_FS 2-2		ND	
Health Sciences Breakroom, CM 2313M	CM_FS 2-3		ND	
Filtration Systems				
Bistro Handsink, counter in sale area	Bistro_SS 1-1		ND	
Bistro Handsink, wall by SW exit to service	Bistro_SS 1-2		ND	
Bistro, Handsink SW wall, wash area	Bistro_SS 1-3		ND	
Bistro, Triple Compartment, Faucet 1	Bistro_SS 1-4		ND	
Bistro, Handsink, SE wall by storage	Bistro_SS 1-5		ND	
Bistro, Spray Sink (Not used for food prep)	Bistro_SS 1-6		ND	
Bistro, Ice Maker	Bistro_IM 1-1		ND	

Location	Sample ID	10/2/2017	9/19/2017	Response
<b>Durham Wellness &amp; Physical Education Center**</b>				
Hydration Stations				
* Main Floor South, Strength/Cardio	DRHM_HS 1-1		ND	
* Main Floor North, Functional 1 & 2	DRHM_HS 1-2		ND	
Showers				
Men's Shower Room, Stall 1	DRHM_SHWR 1-1.1		2	
Men's Shower Room, Stall 2	DRHM_SHWR 1-1.2		1	
Men's Shower Room, Stall 3 (ADA)	DRHM_SHWR1-1.3		2	
Women's Shower Room, Stall 1 (ADA)	DRHM_SHWR 1-2.1		2	
Women's Shower Room, Stall 2	DRHM_SHWR 1-2.2		2	
Women's Shower Room, Stall 3	DRHM_SHWR 1-2.3		2	
<b>Gorman</b>				
Hydration Stations				
1st Flr, Left Unit (while facing)	G_HS 1-1		ND	
1st Flr, Center Unit	G_HS 1-2		ND	
1st Flr, Right Unit (while facing)	G_HS 1-3		ND	
2nd Flr, Left Unit (while facing)	G_HS 2-1		ND	
2nd Flr, Center Unit	G_HS 2-2		ND	
2nd Flr, Right Unit (while facing)	G_HS 2-3		ND	
3rd Flr, Left Unit (while facing)	G_HS 3-1		ND	
3rd Flr, Center Unit	G_HS 3-2		ND	
3rd Flr, Right Unit (while facing)	G_HS 3-3		ND	
Sinks				
Science & Math Division Office Breakroom, G 1001A	G_FS 1-1		ND	
Ice Makers				
Biology, G 1008A	G_IM 1-1		ND	
Physical Sciences, G 3106	G_IM 3-1		ND	
<b>Mott Library</b>				
Hydration Stations				
* 1st Floor by 1016	ML_HS 1-1		ND	
* 1st Floor Events Center	ML_HS 1-2		ND	
* 2nd Floor by Elevator	ML_HS 2-1		ND	
* 2nd Floor by 2202	ML_HS 2-2		ND	
* 3rd Floor by 3003	ML_HS 3-1		ND	
* 3rd Floor by 3202	ML_HS 3-2		ND	
Sinks				
Library Staff Breakroom, ML 1018	ML_FS 1-1		ND	
Events Center Servery, ML 1212A	ML_FS 1-2		ND	
Center for Teaching & Learning, ML 3104	ML_FS 3-1		ND	
Ice Makers				
Events Center Servery, ML 1212A	ML_IM 1-1		ND	

Location	Sample ID	10/2/2017	9/19/2017	Response
<b>Mott Memorial Building</b>				
Hydration Stations				
Terrace Level, Media Services	MMB_HS SB-1		ND	
1st Floor by 1127	MMB_HS 1-1		ND	
1st Floor Main Entrance	MMB_HS 1-2		ND	
1st Floor by 1025	MMB_HS 1-3		ND	
1st Floor Music Wing	MMB_HS 1-4		ND	
2nd Floor by 2129	MMB_HS 2-1		ND	
2nd Floor by 2002	MMB_HS 2-2		ND	
2nd Floor by 2011	MMB_HS 2-3		ND	
2nd Floor by 2019	MMB_HS 2-4		ND	
2nd Floor Dental Wing	MMB_HS 2-5		ND	
Sinks				
Educational Media Services, MMB B010	MMB_FS SB-1		ND	
Early Education Classroom, MMB 2011	MMB_FS 2-1		ND	
Dental Staff Breakroom, MMB 2036A	MMB_FS 2-2		ND	
<b>Prahl College Center</b>				
Hydration Stations				
* Lower Level	PCC_HS B-1		ND	
* 1st Floor Information Desk	PCC_HS 1-1		3	
* 2nd Floor	PCC_HS 2-1		ND	
Sinks				
Culinary Arts Bakery, PCC B280	PCC_FS B-1		ND	
Culinary, SC in Prep PCC B282	PCC_FS B-2		ND	
Culinary Arts DC by Freezer, faucet 1	PCC_FS B-3		ND	
Culinary Arts DC by Freezer, faucet 2	PCC_FS B-4		ND	
Genesee Room, PCC 1230	PCC_FS 1-1	ND	6	Flush, change filter, retest
Veterans Resource Center, PCC 1240A	PCC_FS 1-2		ND	
Counseling & Student Development Breakroom, PCC 2030F	PCC_FS 2-1		ND	
Advising Breakroom, PCC 2060C	PCC_FS 2-2		ND	
Learning Center Breakroom, PCC 2280T	PCC_FS 2-3		ND	
Ice Maker				
Culinary Arts Kitchen	PCC_IM B-1		ND	
Culinary Arts Servery, Applewood	PCC_IM 1-1		ND	
Filtration Systems				
Beanery Handsink, sale area	Beanery_SS 1-1		ND	
Beanery Ice Maker, sale area	Beanery_IM 1-1	ND	9	Flush, check Quest system, retest
Beanery Handsink, prep area	Beanery_SS1-2		1	
Beanery Wash Sink, prep area	Beanery_SS1-3	ND	10	Flush, check Quest system, retest

Location	Sample ID	10/2/2017	9/19/2017	Response
<b>Pappas Presidential Conference Center</b>				
Sinks				
Main Powder Room_109	PRCC_FLS 1-1		ND	
Small Powder Room_102	PRCC_FLS 1-2		ND	
Kitchen Sink_Double	PRCC_FS 1-1		ND	
Kitchen Sink_Single	PRCC_FS 1-2		ND	
Foundation/Community Outreach	PRCC_FLS 2-1		ND	
Ruth Mott VIP Suite	PRCC_FLS 2-2		ND	
MKTG & Development	PRCC_FLS 2-3	ND	7	Flush, retest
Communications & Advancement	PRCC_FLS 2-4	ND	19	Non potable, Flush, change filter, retest
<b>Public Safety</b>				
Hydration Stations				
Vehicle Bay	PS_HS 1-1		ND	
Administrative Hallway	PS_HS 2-1		ND	
Sinks				
Public Safety Staff Breakroom, PS 1003	PS_FS 1-1		ND	
Public Safety Conference Room, PS 2016	PS_FS 2-1		~	No access
<b>Physical Plant Operations</b>				
Sinks				
Kitchen	PPO_FS 1-1		ND	
<b>Regional Technology Center</b>				
Hydrations Stations				
* 1st Floor by 1201	RTC_HS 1-1		ND	
* 1st Floor by 1404	RTC_HS 1-2		ND	
* 1st Floor by 1009	RTC_HS 1-3		ND	
* 2nd Floor by 2201	RTC_HS 2-1		ND	
* 2nd Floor by 2404	RTC_HS 2-2		ND	
* 3rd Floor by 3201	RTC_HS 3-1		ND	
* 3rd Floor by 3604	RTC_HS 3-2		ND	
Sinks				
Student Services Communications, RTC 1302	RTC_FS 1-1		ND	
Community Classroom/Meeting, RTC 1403	RTC_FS 1-2		ND	
RTC Events Servery, RTC 1502	RTC_FS 1-3		ND	
Technology Division Kitchenette, RTC 2700G	RTC_FS 2-1		ND	

Location	Sample ID	10/2/2017	9/19/2017	Response
<b>Visual Arts and Design Center</b>				
Hydration Stations				
North Hallway by Vending	VADC_HS 1-1		ND	
South Hallway between restrooms, Left	VADC_HS 1-2		1	
South Hallway between restrooms, Right	VADC_HS 1-3	ND	6	Flush, change filter, retest
South Hallway by 1118B	VADC_HS 1-4	ND	32	Taken OOS, flush, change filter, retest
Sinks				
Visual Arts & Design Center Breakroom, VADC 100B	VADC_FS 1-1		ND	
Transition's Salon, VADC 119A	VADC_FS 1-2	ND	27	Non potable, flush, change filter, retest
<b>Workforce Education Center (Garfield G. Wagner)</b>				
Hydration Stations				
1st Floor Information Desk	WEC_HS 1-1		ND	
2nd Floor by Restrooms	WEC_HS 2-1		ND	
Sinks				
Workforce Education Center Kitchenette, WAG 2003	WEC_FS 2-1		ND	