



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:10  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03816**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:37	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:12  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03817**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:40	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:13  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03818**

Project Number:

Sample ID: **BFH\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:42	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:17  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03819**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:45	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:15  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03820**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:48	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03821**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:51	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:21  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03822**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:54	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:22  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03823**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:57	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:24  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03824**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-5.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:06	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:25  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03825**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-5.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:09	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:25  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03826**


Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-5.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:21	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:27  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03827**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-6.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:24	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:28  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03828**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-6.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:27	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:29  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03829**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-6.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:30	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:57  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03830**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:33	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 06:58  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03831**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:36	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:01  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03832**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:39	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:02  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03833**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:48	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:03  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03834**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:51	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:05  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03835**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:54	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:06  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03836**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:14	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:07  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503


BA Project # **50225**  
 BA Sample ID **CH03837**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	12:17	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.  
 Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:22  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03838**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:20	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:23  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03839**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:23	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:25  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03840**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:26	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:27  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03841**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:35	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:30  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03842**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:38	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:32  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03843**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:41	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:43  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03844**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:44	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:48  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03845**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:47	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:42  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03846**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:59	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:40  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03847**

Project Number:

Sample ID: **MMB\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:02	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:37  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03848**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:05	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:36  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03849**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:08	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 07:34  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03850**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:17	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:52  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03851**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:20	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:59  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03852**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:23	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:58  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03853**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:26	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:01  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03854**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:29	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:03  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03855**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:32	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:04  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03856**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:52	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:05  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03857**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:55	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:07  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03858**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:04	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:08  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03859**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:07	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:10  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03860**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:10	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:11  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03861**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:13	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:11  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03862**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:16	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:12  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03863**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:19	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:13  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03864**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:22	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:15  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03865**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:25	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 09:43  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03866**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:37	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:41  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03867**


Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:46	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:38  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03868**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:49	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:39  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03869**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:52	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:35  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03870**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM-HS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:55	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:37  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03871**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:58	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:30  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03872**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:01	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:29  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03873**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:04	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:14  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03874**


Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:07	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:15  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03875**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:10	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:17  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03876**


Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:36	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:19  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03877**

Project Number:

Sample ID: **CM\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:39	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:20  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03878**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:42	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:21  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03879**

Project Number:

Sample ID: **CM\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:45	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:23  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03880**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:48	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:24  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03881**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:51	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 08:27  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03882**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:54	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:04  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03883**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:57	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:06  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03884**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:00	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:07  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03885**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:09	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:09  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03886**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:21	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:10  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03887**

Project Number:

Sample ID: **PCC\_FS B-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:24	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:11  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03888**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_IM B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:27	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:29  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03889**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:30	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:30  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03890**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:33	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:31  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03891**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:36	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:34  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03892**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:39	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:40  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03893**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:42	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:41  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03894**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:51	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:38  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03895**

Project Number:

Sample ID: **Beanery\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:54	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:38  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03896**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:14	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:27  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03897**

Project Number:

Sample ID: **PCC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:17	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:17  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03898**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:20	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:19  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03899**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:23	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 10:14  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03900**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:32	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03901**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:35	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:16  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03902**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:38	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:20  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03903**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:41	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:22  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03904**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:44	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:23  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03905**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:47	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:13  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03906**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:59	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:14  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03907**

Project Number:

Sample ID: **ML\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:02	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:06  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03908**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:05	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:09  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03909**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:14	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/17/2018 11:10  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03910**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:17	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:10  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03911**

Project Number:

Sample ID: **G\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:20	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:13  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03912**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:23	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:14  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03913**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:26	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:15  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03914**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:29	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:28  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03915**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:32	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:17  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03916**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:52	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03917**

Project Number:

Sample ID: **G\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:01	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03918**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:04	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:20  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03919**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:07	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:20  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03920**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:10	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:21  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03921**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:13	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:22  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03922**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_IM 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:16	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:49  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03923**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:19	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:40  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03924**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:22	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:42  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03925**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:25	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:42  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03926**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:43	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:44  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03927**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:46	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:45  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03928**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:49	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:46  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03929**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:52	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 10:47  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03930**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:55	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:12  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03931**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:58	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:13  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03932**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:01	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03933**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:04	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03934**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:06	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:20  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03935**


Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:09	04/24/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:23  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03936**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:36	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 11:11  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03937**

Project Number:

Sample ID: **VADC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:39	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 12:39  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03938**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:42	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 12:38  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03939**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:45	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 12:40  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03940**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:48	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 12:43  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03941**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:51	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:00  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03942**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:54	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:17  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03943**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:57	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:18  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03944**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:06	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 12:58  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03945**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:09	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 12:57  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03946**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:21	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:20  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03947**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:24	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:13  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03948**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:27	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:07  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03949**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:30	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:09  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03950**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:33	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:03  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03951**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:36	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:05  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**

Project Name: **20180417 MCC Main Campus**

BA Sample ID **CH03952**

Project Number:

Sample ID: **RTC\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:39	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:36  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03953**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **PPO\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:48	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:59  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03954**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:51	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:58  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03955**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:54	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 4/20/2018 13:57  
 Submit Date/Time: 4/20/2018 15:25  
 Report Date: 4/26/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50225**  
 BA Sample ID **CH03956**

Project Name: **20180417 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:14	04/24/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 4/26/2018