



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:11  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05329**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:55	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:13  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05330**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:58	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:16  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05331**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	11:01	05/18/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:17  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05332**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:04	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:18  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05333**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:07	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:20  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05334**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:10	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:21  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05335**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:13	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:22  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05336**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:16	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:39  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05337**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:25	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:40  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05338**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:28	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:43  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05339**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:40	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:45  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05340**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:43	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:47  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05341**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:46	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:49  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05342**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:49	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:12  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05343**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:52	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:10  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05344**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:55	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:08  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05345**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:58	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:07  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05346**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:07	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:55  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05347**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:10	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:54  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05348**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:13	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 06:52  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05349**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:33	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:46  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05350**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:36	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:44  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05351**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:47	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:45  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05352**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	12:50	05/18/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:41  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05353**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:53	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:40  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05354**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:56	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:37  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05355**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:59	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:35  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05356**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:02	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:33  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05357**

Project Number:

Sample ID: **CM\_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:05	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:15  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05358**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:08	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:17  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05359**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:26	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:20  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05360**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:29	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:22  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05361**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:32	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:23  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05362**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:35	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:24  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05363**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:38	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:30  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05364**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:41	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:12  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05365**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:45	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:10  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05366**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:48	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:07  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05367**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:51	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:08  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05368**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:00	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:03  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05369**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:20	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 08:05  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05370**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:23	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:55  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05371**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:26	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:50  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05372**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:29	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:33  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05373**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:32	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:35  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05374**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:35	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:36  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05375**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:38	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:37  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05376**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:47	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:41  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05377**

Project Number:

Sample ID: **CM\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:50	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:43  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05378**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:53	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:44  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05379**

Project Number:

Sample ID: **CM\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:05	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:46  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05380**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:08	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 07:48  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05381**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:11	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:02  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05382**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:14	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:05  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05383**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:17	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:08  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05384**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:20	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:09  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05385**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:29	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:10  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05386**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:32	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:12  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05387**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **0PCC\_IM B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:35	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:44  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05388**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:38	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:45  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05389**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC-FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:58	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:46  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05390**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:01	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:48  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05391**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:04	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:53  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05392**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:07	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:54  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05393**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:16	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:51  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05394**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	16:19	05/18/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:52  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05395**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:22	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:21  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05396**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:25	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:23  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05397**

Project Number:

Sample ID: **PCC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:28	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:24  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05398**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:31	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 09:40  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05399**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:43	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:47  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05400**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:46	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:45  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05401**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:49	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:43  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05402**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:58	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:42  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05403**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:01	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:42  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05404**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:04	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:39  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05405**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:07	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:37  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05406**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:10	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:31  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05407**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:13	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:33  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05408**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:16	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 10:35  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05409**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:36	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:00  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05410**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:45	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:03  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05411**

Project Number:

Sample ID: **G\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:48	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:04  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05412**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:51	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:05  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05413**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:54	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:26  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05414**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:57	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:08  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05415**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:00	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:09  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05416**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:03	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:09  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05417**

Project Number:

Sample ID: **G\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:06	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:11  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05418**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:09	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:11  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05419**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:27	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:12  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05420**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:30	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:18  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05421**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_IM 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:33	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:36  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05422**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:36	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:42  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05423**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:39	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:44  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05424**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:42	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:47  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05425**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:45	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:52  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05426**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:48	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:51  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05427**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:51	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:50  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05428**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:54	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 11:49  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05429**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:20	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:10  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05430**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:23	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:15  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05431**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:26	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:17  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05432**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:29	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:17  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05433**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:32	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:18  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05434**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:35	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:19  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05435**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:38	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:13  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05436**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:41	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:39  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**

Project Name: **20180515 MCC Main Campus**

BA Sample ID **CH05437**

Project Number:

Sample ID: **PS\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:50	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:40  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05438**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:53	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:42  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05439**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:05	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 12:44  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05440**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:08	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:26  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05441**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:11	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 14:02  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05442**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:14	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:16  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05443**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:17	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:22  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05444**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:20	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:21  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05445**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:23	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:19  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05446**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:32	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:28  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05447**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:35	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:55  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05448**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:38	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 5/21/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:57  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05449**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:58	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:50  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05450**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:01	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 13:52  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05451**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:04	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 14:22  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05452**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **PPO\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:07	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 14:44  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05453**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:10	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 14:40  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05454**


Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:19	05/18/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 5/21/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 05/15/2018 14:38  
 Submit Date/Time: 05/15/2018 16:00  
 Report Date: 05/21/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **50624**  
 BA Sample ID **CH05455**

Project Name: **20180515 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:22	05/18/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/21/2018