



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 09:09
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06610**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **NTC_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:45	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 09:13
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**

Project Name: **20180605 MCC SITES**

BA Sample ID **CH06611**

Project Number:

Sample ID: **NTC_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:48	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 09:15
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06612**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **NTC_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:51	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 09:12
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06613**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **NTC_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:54	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:10
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06614**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **HTC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:57	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 09:57
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06615**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **HTCFP_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:00	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 09:58
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06616**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **HTCFP_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:09	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:26
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06617**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_111 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:12	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:24
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06618**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_110 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:15	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:31
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06619**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_109 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:18	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:38
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06620**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_108 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:39	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:39
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06621**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_106 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:41	06/06/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:40
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06622**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_107 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:44	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:42
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06623**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_105 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:47	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:43
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06624**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_103 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:56	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:46
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06625**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_104 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:59	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:47
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06626**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_102 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:02	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:48
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06627**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_101 S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	18:05	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 10:28
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06628**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **ECD_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:08	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 11:29
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06629**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **DN_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:11	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 11:35
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06630**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **DN_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:23	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:18
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503


BA Project # **51001** Project Name: **20180605 MCC SITES**
 BA Sample ID **CH06631** Project Number:
 Sample ID: **SLB_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:26	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:19
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06632**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	18:29	06/06/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:22
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06633**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	18:38	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:24
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06634**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:41	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:29
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06635**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:44	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:31
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06636**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:47	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:32
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06637**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:50	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:26
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06638**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	18:53	06/06/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:27
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06639**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_S 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	3	ug/L	1	15	EPA 200.8 rev5.4	18:56	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:44
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06640**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLB_DF 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:17	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 12:47
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06641**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **SLC_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:26	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 13:56
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06642**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:29	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 14:00
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06643**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:32	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 14:01
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06644**


Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:35	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 14:10
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06645**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:38	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 14:11
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06646**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:41	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 15:08
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06647**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:43	06/06/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 06/05/2018 15:09
 Submit Date/Time: 06/05/2018 15:45
 Report Date: 06/22/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **51001**
 BA Sample ID **CH06648**

Project Name: **20180605 MCC SITES**
 Project Number:
 Sample ID: **LIV_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:46	06/06/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/22/2018