



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:03  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07895**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:52	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:25  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07896**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:55	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:26  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07897**

Project Number:

Sample ID: **BFH\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:58	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:04  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07898**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:01	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:07  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07899**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	12:10	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:09  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07900**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:13	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:10  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07901**

Project Number:

Sample ID: **BFH\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:16	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:12  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07902**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:37	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:14  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07903**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-5.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:40	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:15  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07904**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-5.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:43	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:15  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07905**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-5.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:46	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:18  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07906**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-6.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:49	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:20  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07907**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-6.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:57	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:21  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07908**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **BFH\_SHWR 1-6.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:00	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:37  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07909**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:03	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:39  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07910**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:06	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:42  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07911**

Project Number:

Sample ID: **DRHM\_SHWR 1-1.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:09	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:43  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07912**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	13:21	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:44  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07913**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:24	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:42  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07914**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:27	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:41  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07915**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:30	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 06:40  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07916**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **DRHM\_SHWR 1-2.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:39	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:05  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07917**

Project Number:

Sample ID: **MMB\_FS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:42	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:14  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07918**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:45	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:32  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07919**

Project Number:

Sample ID: **MMB\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:48	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:02  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07920**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:51	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:30  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07921**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:54	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:29  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07922**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:14	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:16  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07923**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:17	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:19  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07924**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:26	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:20  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07925**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:29	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:21  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07926**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:32	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:24  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07927**

Project Number:

Sample ID: **MMB\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:35	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:25  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07928**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:38	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:26  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07929**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **MMB\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:41	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:32  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07930**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:44	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:30  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07931**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:47	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:30  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07932**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:59	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:27  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07933**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:08	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:26  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07934**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:10	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:25  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07935**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:13	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:24  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07936**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:16	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:17  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07937**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:19	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:51  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07938**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:22	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:52  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07939**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:25	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:53  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07940**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:28	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:53  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07941**

Project Number:

Sample ID: **Bistro\_SS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:31	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:54  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07942**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:58	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:55  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07943**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_SS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:01	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:56  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07944**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Bistro\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:04	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:48  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07945**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:07	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:43  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07946**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:10	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:40  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07947**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:13	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:42  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07948**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:16	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:38  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07949**

Project Number:

Sample ID: **CM\_HS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:19	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:39  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07950**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:21	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:35  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07951**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:30	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:34  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07952**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:42	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:35  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07953**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:45	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:37  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07954**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:48	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:38  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07955**

Project Number:

Sample ID: **CM\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:51	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:40  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07956**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:54	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:41  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07957**

Project Number:

Sample ID: **CM\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:57	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:42  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07958**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:00	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:44  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07959**

Project Number:

Sample ID: **CM\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:03	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:45  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07960**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **CM\_HS 2-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:12	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 09:47  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07961**

Project Number:

Sample ID: **CM\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:15	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 13:57  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07962**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:35	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 13:58  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07963**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:38	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:02  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07964**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:41	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:03  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07965**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:44	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:03  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07966**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS B-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:47	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:06  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07967**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_IM B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:50	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:22  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07968**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:59	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:23  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07969**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:02	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:25  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07970**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:05	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:27  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07971**

Project Number:

Sample ID: **PCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:08	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:32  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07972**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:20	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:33  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07973**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:23	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:30  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07974**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:26	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:31  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07975**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **Beanery\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:29	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:13  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07976**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:32	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:15  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07977**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:41	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:17  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07978**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:43	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 14:11  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07979**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PCC\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:46	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:19  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07980**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:49	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:18  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07981**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:52	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:16  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07982**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:13	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:14  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07983**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:16	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:15  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07984**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:19	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:04  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07985**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:28	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:06  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07986**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:31	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 07:58  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**

Project Name: **20180626 MCC Main Campus**

BA Sample ID **CH07987**

Project Number:

Sample ID: **ML\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:34	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:01  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07988**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML-FS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:37	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 08:02  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07989**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **ML\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:40	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:15  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07990**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:43	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:22  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07991**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:46	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:23  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07992**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:57	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:23  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07993**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:00	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:39  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07994**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:09	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:26  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07995**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:12	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:26  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07996**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:15	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:27  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07997**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:18	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:30  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07998**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:21	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:31  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH07999**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:24	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:31  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08000**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_HS 3-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:27	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:33  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08001**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **G\_IM 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:30	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 10:58  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08002**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	20:56	06/28/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:00  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08003**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:59	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:01  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08004**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:02	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:01  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08005**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:05	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:07  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08006**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:08	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:06  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08007**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:11	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:05  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08008**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:14	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:03  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08009**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PRCC\_FLS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:17	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:29  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08010**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:20	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:23  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08011**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:23	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:31  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08012**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:41	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:32  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08013**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:44	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:34  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08014**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:47	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:35  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08015**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:50	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:27  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08016**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **VADC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:53	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:47  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08017**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:56	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:49  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08018**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:59	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:56  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08019**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:02	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 11:57  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08020**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PS\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:05	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:19  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08021**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:14	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:16  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08022**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:34	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:15  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08023**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:37	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:42  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08024**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:40	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:40  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08025**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:43	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:38  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08026**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:46	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:21  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08027**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:49	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:26  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08028**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:52	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:24  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08029**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:01	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:29  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08030**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:04	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:32  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08031**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **RTC\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:07	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 12:45  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08032**


Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **PPO\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:19	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 13:32  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08033**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:22	06/28/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 13:24  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08034**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:25	06/28/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/26/2018 13:22  
 Submit Date/Time: 06/26/2018 15:30  
 Report Date: 06/29/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **51402**  
 BA Sample ID **CH08035**

Project Name: **20180626 MCC Main Campus**  
 Project Number:  
 Sample ID: **WEC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	23:28	06/28/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 6/29/2018