



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 09/17/2018 08:44
 Submit Date/Time: 09/18/2018 15:30
 Report Date: 09/21/2018

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **52840**
 BA Sample ID **CI03093**

Project Name: **20180917 LAPR Retest MCC**
 Project Number:
 Sample ID: **LAPR-S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:44	09/21/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 9/21/2018