



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:38  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04144**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:38	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:40  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04145**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	11:41	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:42  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04146**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	11:44	10/05/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:43  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04147**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:47	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:44  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04148**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_S 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:50	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:48  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04149**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	11:53	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 07:51  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04150**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LAPR\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:56	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 08:54  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04151**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **NTC\_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:59	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 08:58  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04152**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **NTC\_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:08	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 09:02  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04153**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **NTC\_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:11	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 09:02  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04154**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **NTC\_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:23	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 09:54  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04155**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **GLBC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:26	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:10  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04156**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **HTC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:29	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:14  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04157**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **HTCFP\_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:32	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:15  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04158**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **HTCFP\_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	12:35	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:33  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04159**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_111 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:38	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:35  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04160**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_110 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:41	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:36  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04161**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_109 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:50	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:39  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04162**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_108 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:53	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:40  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04163**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_106 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:56	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:42  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04164**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_107 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:16	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:43  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04165**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_105 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:19	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:45  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04166**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_103 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:22	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:46  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04167**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_104 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:25	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:47  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04168**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_102 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:28	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:49  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04169**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_101 S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	3	ug/L	1	15	EPA 200.8 rev5.4	13:37	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 11:00  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04170**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **ECD\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:40	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 11:23  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04171**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **DN\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:43	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 11:26  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04172**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **DN\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:46	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:08  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04173**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:49	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:10  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04174**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	14:01	10/05/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:11  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04175**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	14:04	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:12  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04176**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:07	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:16  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04177**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:10	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:18  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04178**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:19	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:19  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04179**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:22	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:14  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04180**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	5	ug/L	1	15	EPA 200.8 rev5.4	14:25	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:15  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04181**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_S 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	3	ug/L	1	15	EPA 200.8 rev5.4	14:28	10/05/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:23  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04182**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLB\_DF 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	14:31	10/05/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:25  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04183**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLC\_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:34	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:23  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04184**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:54	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:24  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04185**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:57	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:24  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04186**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:09	10/05/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:27  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04187**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:12	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:28  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04188**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:15	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:37  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04189**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:18	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 14:38  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04190**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **LIV\_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:21	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 10:16  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04191**


Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **HTCFP FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:24	10/05/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 10/8/2018





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 10/02/2018 13:17  
 Submit Date/Time: 10/02/2018 15:10  
 Report Date: 10/08/2018

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **53142**  
 BA Sample ID **CI04192**

Project Name: **20181002 MCC Sites**  
 Project Number:  
 Sample ID: **SLC S 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	15:27	10/05/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 10/8/2018