



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:03
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00911**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:09	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:04
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00912**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_IM 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:18	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:05
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00913**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-7.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:21	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:06
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00914**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-7.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	17:24	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:07
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00915**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-7.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:27	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:08
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00916**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-8.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:30	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:09
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00917**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-8.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:33	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00918**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-8.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:36	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:12
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00919**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:57	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:14
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00920**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:06	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:15
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00921**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:09	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:19
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00922**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:12	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:21
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00923**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:15	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:22
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00924**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	18:18	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:23
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00925**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:20	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:24
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00926**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:23	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:27
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00927**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	3	ug/L	1	15	EPA 200.8 rev5.4	18:26	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:28
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00928**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:29	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:30
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00929**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:47	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:31
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00930**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:50	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:41
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00931**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:53	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:42
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00932**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-5.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	18:56	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:42
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00933**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-5.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	18:59	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:43
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00934**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-5.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:02	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:56
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00935**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-6.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:05	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:57
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00936**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-6.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	19:08	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 06:58
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00937**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-6.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:11	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:12
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00938**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:14	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:11
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00939**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:40	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:15
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00940**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-1.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	19:43	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:16
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00941**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-1.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	19:46	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:17
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00942**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	19:49	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:20
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00943**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-2.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	19:52	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:21
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00944**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-2.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	19:55	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:21
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00945**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-2.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	19:58	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:42
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00946**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:01	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:41
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00947**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_FS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:10	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:46
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00948**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:13	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:49
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00949**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	20:25	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 07:51
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00950**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:28	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:00
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00951**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:31	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:02
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00952**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:34	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:03
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00953**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:37	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:05
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00954**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	20:40	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:06
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00955**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	20:43	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:07
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00956**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:52	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00957**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:55	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:24
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00958**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:58	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:29
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00959**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM-HS 2-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:18	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:30
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00960**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	21:21	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:32
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00961**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:24	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:43
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00962**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:27	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:35
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00963**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:30	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:45
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00964**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:39	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:46
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00965**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:42	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:47
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00966**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:45	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:50
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00967**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:48	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:51
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00968**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:51	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:52
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00969**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	22:03	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:58
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00970**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:06	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 08:57
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00971**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:09	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:00
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00972**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:12	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:07
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00973**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:21	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:05
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00974**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:24	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00975**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:27	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:11
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00976**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:30	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:13
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00977**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:33	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:12
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00978**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:36	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:14
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00979**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:57	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:15
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00980**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:00	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:16
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00981**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:09	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:18
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00982**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:12	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:46
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00983**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:15	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:48
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00984**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:18	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:47
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00985**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:21	12/19/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:50
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00986**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:24	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:51
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00987**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:27	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:53
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00988**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:30	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 09:54
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00989**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **CM_S 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	23:41	12/19/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:06
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00990**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_HS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:50	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00991**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:53	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:11
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00992**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:56	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:13
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00993**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:59	12/19/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:13
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00994**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:02	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:15
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00995**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_IM B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:05	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:20
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00996**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:08	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:21
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00997**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:11	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:23
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00998**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:14	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:28
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ00999**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:41	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:30
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01000**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:44	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:32
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01001**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:47	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:33
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01002**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:50	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:35
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01003**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:53	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:39
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01004**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:56	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:36
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01005**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:59	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:38
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01006**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:02	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:37
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01007**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:05	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:57
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01008**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:14	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:58
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01009**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_FS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:26	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 10:59
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01010**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:29	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:01
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01011**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:32	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:02
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01012**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:35	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:08
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01013**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:38	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01014**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	01:41	12/20/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:06
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01015**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:44	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:04
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01016**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:47	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:06
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01017**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **ML_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:56	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:22
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01018**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	01:59	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:24
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01019**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:19	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:24
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01020**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:23	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:25
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01021**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:25	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:39
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01022**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:28	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:27
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01023**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:31	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:28
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01024**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:34	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:28
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01025**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:43	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:34
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01026**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:46	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:34
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01027**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:49	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:35
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01028**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 3-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	02:52	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:36
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01029**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **G_IM 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:04	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:54
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01030**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:07	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:55
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01031**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:10	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:56
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01032**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	03:13	12/20/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:57
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01033**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	03:16	12/20/2018
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:04
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01034**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:25	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:03
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01035**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:28	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:02
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01036**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:31	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 11:59
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01037**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:34	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:32
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01038**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:37	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:35
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01039**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	03:58	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:34
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01040**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:01	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:38
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01041**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:04	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:38
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01042**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:13	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:39
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01043**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:16	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:40
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01044**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:19	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:13
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503


BA Project # **54710** Project Name: **201812 MCC Main Campus**
 BA Sample ID **CJ01045** Project Number:
 Sample ID: **PS_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:22	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:14
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01046**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PS_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:24	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:15
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01047**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PS_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:27	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 12:16
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01048**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PS_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:30	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:42
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01049**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:42	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:44
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01050**


Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	04:45	12/20/2018

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:09
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01051**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:54	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01052**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	04:57	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:14
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01053**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:00	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:21
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01054**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:03	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:24
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01055**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:06	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:30
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01056**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:09	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:33
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01057**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:12	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:37
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01058**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:15	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 13:55
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01059**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:42	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 14:10
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01060**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **PPO_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:45	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 14:40
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01061**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **WEC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:48	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 14:35
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01062**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **WEC_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:51	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 12/18/2018 14:36
 Submit Date/Time: 12/18/2018 15:45
 Report Date: 01/15/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **54710**
 BA Sample ID **CJ01063**

Project Name: **201812 MCC Main Campus**
 Project Number:
 Sample ID: **WEC_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	05:54	12/20/2018
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/15/2019