

Potable water testing for lead was done on, November 13, 2018 at the following drinking fountains, and sinks at Mott Community College site locations. Samples were collected by MCC's Risk Management personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.

pb = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected

EPA maximum allowable level for lead - 15 ppb

MCC cautionary level for potable water = 5 ppb, at which time remedial action will be taken

OOO - Out of Order

| Location | Sample ID | 11/13/2018 | Response |
|--------------------------------------|---------------|------------|----------|
| Lapeer | | | |
| Drinking Fountains | | | |
| Large Commons, C320 | LAPR_HS 1-1 | ND | |
| Small Commons, MiWorks! | LAPR_HS 1-2 | ND | |
| Sinks | | | |
| Staff Breakroom, LAPR C314 | LAPR_FS 1-1 | ND | |
| LAPR C317 | LAPR_S 1-2 | ND | |
| Staff Kitchenette, LAPR B206 | LAPR_S 1-3 | ND | |
| Continuing Education, B218 | LAPR_S 1-4 | 1 | |
| Michigan Works!, A101 | LAPR_S 1-5 | ND | |
| Northern Tier Center | | | |
| Drinking Fountains | | | |
| Commons, Drinking Fountain 1 (Left) | NTC_DF 1-1 | ND | |
| Commons, Drinking Fountain 2 (Right) | NTC_DF 1-2 | ND | |
| Sinks | | | |
| Main Office Kitchenette, NTC 105 | NTC_S 1-1 | ND | |
| Servery, NTC 113A | NTC_S 1-2 | ND | |
| Great Lakes Baptist | | | |
| Sinks | | | |
| Kitchenette | GLBC_FS 1-1 | ND | |
| Hispanic Community Center | | | |
| Sink | | | |
| Main Building Kitchen | HTC_FS 1-1 | ND | |
| Food Pantry Sink | HTC_FP_FS 1-1 | ND | |
| Drinking Fountain | | | |
| Food Pantry - Left | HTC_FP_DF 1-1 | ND | |
| Food Pantry - Right | HTC_FP_DF 1-2 | 2 | |

Disability Network

Hydration Stations

| | | |
|------------|-----------|----|
| Main Entry | DN_HS 1-1 | ND |
|------------|-----------|----|

Sink

| | | |
|-------------|-----------|----|
| Kitchenette | DN_FS 1-1 | ND |
|-------------|-----------|----|

Southern Lakes Branch Campus

Drinking Fountains

| | | |
|-----------------------------|------------|---|
| Hallway by 1104, West Entry | SLB_DF 1-1 | 1 |
|-----------------------------|------------|---|

| | | |
|-------------|------------|-----|
| Within 1104 | SLB_DF 1-2 | OOS |
|-------------|------------|-----|

| | | |
|-----------------|------------|----|
| Hallway by 1004 | SLB_DF 1-3 | ND |
|-----------------|------------|----|

| | | |
|-----------------|------------|---|
| Hallway by 1304 | SLB_DF 1-4 | 1 |
|-----------------|------------|---|

| | | |
|---------------------------------------|------------|----|
| Drinking Fountain by 1104, East Entry | SLB_DF 1-5 | ND |
|---------------------------------------|------------|----|

| | | |
|------------------------------|------------|----|
| Academy Fountain, building C | SLC_DF 1-1 | ND |
|------------------------------|------------|----|

Sinks

| | | |
|------------------------|------------|----|
| Staff Breakroom, 1104A | SLB_FS 1-1 | ND |
|------------------------|------------|----|

| | | |
|---------------------------|-----------|----|
| PTA/OTA 1012, Kitchenette | SLB_S 1-2 | ND |
|---------------------------|-----------|----|

| | | |
|--------------|-----------|---|
| PTA/OTA 1016 | SLB_S 1-3 | 1 |
|--------------|-----------|---|

| | | |
|--------------|------------|----|
| PTA/OTA 1502 | SLB_FS 1-4 | ND |
|--------------|------------|----|

| | | |
|-------------------|-----------|---|
| PTA/OTA 1014 Left | SLB_S 1-5 | 1 |
|-------------------|-----------|---|

| | | |
|--------------------|-----------|---|
| PTA/OTA 1014 Right | SLB_S 1-6 | 3 |
|--------------------|-----------|---|

| | | |
|------------------------|----------|---|
| PTA/OTA Classroom 1011 | SLB_S1-7 | 2 |
|------------------------|----------|---|

Livingston MTEC

Hydration Stations

| | | |
|---------------------------------|------------|----|
| Hallway by Restrooms, Left unit | LIV_DF 1-1 | ND |
|---------------------------------|------------|----|

| | | |
|----------------------------------|------------|----|
| Hallway by Restrooms, Right unit | LIV_DF 1-2 | ND |
|----------------------------------|------------|----|

| | | |
|--------------------|------------|----|
| Highbay, Left Unit | LIV_DF 1-3 | ND |
|--------------------|------------|----|

| | | |
|---------------------|------------|----|
| Highbay, Right Unit | LIV_DF 1-4 | ND |
|---------------------|------------|----|

Sinks

| | | |
|-------------------|-----------|----|
| Staff Kitchenette | LIV_S 1-1 | ND |
|-------------------|-----------|----|

| | | |
|---|-----------|----|
| Certified Aide Classroom 105, Left sink | LIV_S 1-2 | ND |
|---|-----------|----|

| | | |
|--|-----------|----|
| Certified Aide Classroom 105, Right sink | LIV_S 1-3 | ND |
|--|-----------|----|

Family Life Center (Woodside Church)

| Sinks | | |
|-----------------------|----------------|----|
| ECD Literacy Room | ECD_111 FS 1-1 | ND |
| ECD Main Office | ECD_110 FS 1-1 | ND |
| ECD Director Office | ECD_109 FS 1-1 | ND |
| ECD "Red Room" | ECD_108 FS 1-1 | ND |
| ECD "Red Room" | ECD_106 FS 1-1 | ND |
| ECD "Green Room" | ECD_107 FS 1-1 | ND |
| ECD "Green Room" | ECD_105 FS 1-1 | ND |
| ECD Storage | ECD_103 FS 1-1 | ND |
| ECD "Yellow Room" | ECD_104 FS 1-1 | ND |
| ECD "Yellow Room" | ECD_102 FS 1-1 | ND |
| ECD Resource Room | ECD_101 S 1-1 | 2 |
| Hydration Stations | | |
| ECD Hydration Station | ECD_HS 1-1 | ND |