



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 05:57  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02093**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:01	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 05:58  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02094**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_IM 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:04	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 05:59  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02095**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-7.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:07	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:00  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02096**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-7.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:10	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:01  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02097**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-7.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:13	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:03  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02098**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-8.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:22	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:04  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02099**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-8.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:25	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:05  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02100**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-8.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:28	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:06  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02101**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:49	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:08  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02102**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:52	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:09  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02103**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:55	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:11  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02104**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:58	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:13  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02105**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:01	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:14  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02106**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:09	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:16  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02107**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:12	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:16  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02108**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:15	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:17  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02109**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:18	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:18  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02110**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:21	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:20  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02111**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:33	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:22  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02112**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:36	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:23  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02113**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:39	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:26  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02114**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-5.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:42	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:27  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02115**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-5.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:51	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:27  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02116**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-5.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:54	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:29  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02117**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-6.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:57	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:30  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02118**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-6.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:00	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:31  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02119**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **BFH\_SHWR 1-6.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:03	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:38  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02120**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:06	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:39  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02121**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:26	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:40  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02122**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_SHWR 1-1.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:29	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:41  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02123**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_SHWR 1-1.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:38	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:42  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02124**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_SHWR 1-1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:41	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:54  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02125**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_SHWR 1-2.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:44	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:45  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02126**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_SHWR 1-2.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	17:47	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 06:46  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02127**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **DRHM\_SHWR 1-2.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:50	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:06  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02128**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:53	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:05  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02129**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_FS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:56	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:08  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02130**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:59	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:00  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02131**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:11	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:10  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02132**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:20	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:12  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02133**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:23	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:19  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02134**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:26	01/17/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:21  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02135**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:29	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:23  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02136**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:32	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:25  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02137**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:35	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:26  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02138**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:38	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:27  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02139**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:41	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:29  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02140**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **MMB\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:44	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:54  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02141**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:47	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:55  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02142**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 2-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:50	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:57  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02143**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:53	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:58  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02144**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:56	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:03  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02145**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	10:59	01/18/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:00  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02146**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:02	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:04  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02147**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:05	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:05  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02148**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:08	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:07  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02149**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:17	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:09  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02150**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:20	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:12  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02151**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:32	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:11  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02152**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:35	01/18/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:14  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02153**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:38	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:16  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02154**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:41	01/18/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 \_\_\_\_\_  
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:17  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02155**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:44	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:18  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02156**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:47	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:27  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02157**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:50	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:30  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02158**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:58	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:32  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02159**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:01	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:33  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02160**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:17	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:34  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02161**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_SS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:38	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:35  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02162**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_SS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:41	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:32  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02163**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_SS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:44	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:37  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02164**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Bistro\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:47	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:05  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02165**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:50	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:01  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02166**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:59	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:57  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02167**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:02	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:59  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02168**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:05	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:54  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02169**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:08	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 08:55  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02170**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:11	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:45  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02171**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_HS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:22	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 07:42  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02172**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **CM\_S 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:25	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:15  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02173**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_HS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:28	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:17  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02174**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:31	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:18  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02175**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS B-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:40	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:22  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02176**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS B-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:43	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:23  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02177**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS B-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:46	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:24  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02178**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_IM B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:49	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:28  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02179**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:52	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:30  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02180**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:55	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:31  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02181**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:25	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:33  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02182**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:28	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:49  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02183**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:31	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:55  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02184**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:40	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:57  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02185**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:43	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 09:59  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02186**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:46	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:02  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02187**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Beanery\_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:49	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:03  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02188**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Beanery\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:52	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:00  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02189**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Beanery\_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:55	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:01  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02190**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **Beanery\_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:58	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:31  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02191**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:10	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:32  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02192**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_FS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:13	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:33  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02193**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:22	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:35  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02194**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:25	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:37  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02195**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:28	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:44  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02196**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:31	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:46  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02197**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:34	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:39  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02198**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:37	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:41  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02199**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **ML\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:39	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:26  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02200**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:42	01/17/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:29  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02201**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:16	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:30  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02202**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:19	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:30  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02203**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:28	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:43  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02204**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:30	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:39  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02205**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:33	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:40  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02206**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:36	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:41  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02207**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:39	01/18/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:33  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02208**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:42	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:34  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02209**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:45	01/18/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:34  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02210**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_HS 3-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:48	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:36  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02211**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **G\_IM 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:00	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:52  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02212**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FLS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	15:12	01/18/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:53  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02213**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FLS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:15	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:54  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02214**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:18	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:55  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02215**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:21	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:59  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02216**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FLS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:24	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:58  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02217**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FLS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:27	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:58  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02218**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FLS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:30	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:56  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02219**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PRCC\_FLS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:33	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 10:59  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02220**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:36	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:02  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02221**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:03	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:01  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02222**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:06	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:05  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02223**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:09	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:06  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02224**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:12	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:07  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02225**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:15	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 11:08  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02226**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **VADC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:18	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:08  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02227**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PS\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:21	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:09  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02228**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PS\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:24	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:11  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02229**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PS\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:27	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:12  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02230**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PS\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:36	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:52  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02231**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:50	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:54  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02232**


Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:53	01/18/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:33  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02233**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:56	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:34  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02234**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:59	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:36  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02235**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:02	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:38  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02236**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:05	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:39  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02237**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:08	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:42  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02238**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:14	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:43  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02239**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:23	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:48  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02240**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:26	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 12:46  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02241**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **RTC\_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:47	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 13:19  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02242**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **PPO\_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:50	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 13:56  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02243**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **WEC\_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:53	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 13:51  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02244**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **WEC\_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:56	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019





**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 01/15/2019 13:52  
 Submit Date/Time: 01/15/2019 14:50  
 Report Date: 01/21/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **55125**  
 BA Sample ID **CJ02245**

Project Name: **Mott Community College**  
 Project Number: **201901 MCC Main Campus**  
 Sample ID: **WEC\_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

**Drinking Water Metal Analysis**

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:02	01/18/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 1/21/2019