



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 07:49
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04989**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:23	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 07:51
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04990**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	11:26	03/08/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 07:58
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04991**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:29	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 08:00
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04992**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:32	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 08:01
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04993**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_S 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	11:35	03/08/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 08:05
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04994**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:37	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 08:07
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04995**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LAPR_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:40	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 09:18
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04996**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **NTC_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	11:43	03/08/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 09:22
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04997**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **NTC_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:52	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 09:27
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04998**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **NTC_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:55	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 09:27
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ04999**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **NTC_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:07	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:30
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05000**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **HTC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:10	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:25
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05001**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **HTCFP_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:13	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:25
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05002**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **HTCFP_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:16	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:52
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05003**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_111 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:19	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:50
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05004**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_110 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:22	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:55
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05005**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_109 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:25	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:57
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05006**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_108 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:34	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:58
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05007**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_106 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:37	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:00
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05008**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_107 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:40	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:01
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05009**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_105 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:00	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:02
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05010**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_103 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:03	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:03
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05011**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_104 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:06	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:04
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05012**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_102 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:09	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:06
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05013**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_101 FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:12	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:53
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05014**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **ECD_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:21	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:26
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05015**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **DN_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:24	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 11:28
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05016**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **DN_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:27	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:19
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05017**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:30	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:20
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05018**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:33	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:22
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05019**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	13:45	03/08/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:23
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05020**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	13:48	03/08/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:29
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05021**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:51	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:31
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05022**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:53	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:32
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05023**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:02	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:25
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05024**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:05	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:26
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05025**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_S 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	3	ug/L	1	15	EPA 200.8 rev5.4	14:08	03/08/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:37
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05026**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB_DF 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:11	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:41
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05027**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SBC_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:14	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:31
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05028**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:17	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:43
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05029**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:38	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:44
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05030**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:41	03/08/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:53
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05031**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:50	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:54
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05032**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:53	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:57
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05033**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:56	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 13:58
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05034**


Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **LIV_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:59	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 10:23
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05035**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **HTCFP FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:02	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 03/05/2019 12:22
 Submit Date/Time: 03/05/2019 14:40
 Report Date: 03/11/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **55871**
 BA Sample ID **CJ05036**

Project Name: **Mott Community College**
 Project Number: **201903 MCC Sites**
 Sample ID: **SLB FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:04	03/08/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 3/11/2019