



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:37
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01038**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:44	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:40
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01039**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	15:47	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:42
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01040**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	15:50	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:44
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01041**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:53	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:47
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01042**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_S 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	16:20	05/09/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:48
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01043**


Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	16:23	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 07:52
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01044**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LAPR_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:26	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 08:53
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01045**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **NTC_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:29	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 08:55
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01046**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **NTC_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:32	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 08:57
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01047**


Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **NTC_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	16:35	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 08:58
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01048**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **NTC_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:38	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 09:45
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01049**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **GLBC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:40	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:06
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01050**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **HTC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:43	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:02
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01051**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **HTCFP_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:52	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:03
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01052**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **HTCFP_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:04	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 12:05
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01053**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **DN_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:07	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 12:11
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01054**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **DN_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:10	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:09
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01055**


Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:13	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:11
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01056**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:16	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:13
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01057**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:19	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:15
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01058**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:22	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:20
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01059**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:25	05/09/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:24
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01060**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:34	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:27
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01061**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:37	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:18
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01062**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	17:57	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:18
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01063**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_S 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	3	ug/L	1	15	EPA 200.8 rev5.4	18:00	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:31
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01064**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLB_DF 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:03	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:35
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01065**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLC_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:06	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:36
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01066**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_S 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	18:09	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:34
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01067**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_S 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:12	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:34
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01068**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_S 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:21	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:40
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01069**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_DF 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:24	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:40
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01070**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_DF 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:27	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:55
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01071**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_DF 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:30	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 14:55
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01072**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **LIV_DF 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:42	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 13:21
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01073**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **SLBC_S1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	18:45	05/09/2019
-----------------------------	---	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:36
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01074**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **ECD_Red Room**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:47	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:32
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01075**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **ECD_Blue Room**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:50	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:36
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01076**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **ECD_Yellow Room**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:53	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:33
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01077**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **ECD_Green Room**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:02	05/09/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 05/07/2019 10:00
 Submit Date/Time: 05/07/2019 15:15
 Report Date: 05/10/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **57818**
 BA Sample ID **CK01078**

Project Name: **Mott Community College**
 Project Number: **201905 MCC Sites**
 Sample ID: **HTCFP_S1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:05	05/09/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 5/10/2019