



**Brighton Analytical LLC**  
 2105 Pless Drive  
 Brighton, Michigan 48114  
 Phone: (810)229-7575 (810)229-8650  
 e-mail: bai-brighton@sbcglobal.net  
 MDNRE Certified #9404  
 NELAC Accredited #176507

Sample Date/Time: 06/04/2019 10:50  
 Submit Date/Time: 06/04/2019 15:15  
 Report Date: 06/06/2019

Mott Community College  
 1401 East Court St.  
 Flint, MI 48503

BA Project # **58887**  
 BA Sample ID **CK03026**


Project Name: **Mott Community College**  
 Project Number: **201906\_DRHM Retest**  
 Sample ID: **DRHM SHWR 1.1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
<b>Drinking Water Metal Analysis</b>							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	11:42	06/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by   
 Date 6/6/2019