



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:19
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06863**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_S 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:15	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:20
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06864**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_IM 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:18	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:22
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06865**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-7.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:21	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:23
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06866**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-7.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	12:24	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:24
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06867**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-7.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:27	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:25
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06868**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-8.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:30	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:26
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06869**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-8.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:33	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:27
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06870**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-8.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:36	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:28
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06871**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:45	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:29
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06872**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BHF_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	12:48	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:30
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06873**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:00	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:31
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06874**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:03	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:33
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06875**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	2	ug/L	1	15	EPA 200.8 rev5.4	13:06	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:34
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06876**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:09	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:36
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06877**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:12	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:38
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06878**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:15	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:40
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06879**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-5.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:18	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:40
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06880**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-5.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:27	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 06:41
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06881**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **BFH_SHWR 1-5.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:30	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:00
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06882**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:33	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:01
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06883**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:53	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:03
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06884**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-1.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:56	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:03
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06885**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-1.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	13:59	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:04
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06886**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-1.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:02	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:06
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06887**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-2.1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:05	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:07
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06888**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-2.2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:14	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:08
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06889**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **DRHM_SHWR 1-2.3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:17	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:29
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06890**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:20	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:28
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06891**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_FS SB-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:23	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:26
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06892**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:26	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:50
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06893**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:38	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:32
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06894**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:41	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:33
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06895**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:44	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:39
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06896**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:47	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:42
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06897**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:56	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:43
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06898**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	14:59	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:44
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06899**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:02	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:45
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06900**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:05	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:49
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06901**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:08	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 07:47
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06902**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **MMB_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:11	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:02
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06903**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:31	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:04
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06904**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:34	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:05
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06905**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:43	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:09
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06906**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:46	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:14
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06907**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:49	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:11
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06908**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:52	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:16
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06909**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:55	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:17
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06910**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	15:58	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:19
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**

Project Name: **201907 MCC Main Campus**

BA Sample ID **CK06911**

Project Number:

Sample ID: **CM_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:01	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:21
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06912**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:04	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:23
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06913**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:16	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:22
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06914**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:25	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:26
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06915**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:28	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:27
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06916**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:31	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:28
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06917**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:34	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:29
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06918**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:37	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:37
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06919**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:40	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:40
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06920**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:43	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:41
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06921**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:46	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:42
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06922**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	16:49	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:43
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06923**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:15	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:43
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06924**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:18	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:45
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06925**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_SS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:21	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:46
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06926**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Bistro_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:24	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:53
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06927**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:27	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:55
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06928**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-5**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:30	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:57
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06929**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:33	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 08:58
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06930**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-6**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:36	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:00
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06931**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:39	12/30/1999
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:02
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06932**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-7**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	17:48	12/30/1999

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:03
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06933**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_HS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:00	12/30/1999

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:04
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06934**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **CM_FS 1-8**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:03	12/30/1999
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:09
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06935**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_HS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:06	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:04
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06936**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:09	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:06
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06937**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:12	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:07
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06938**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:15	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:08
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06939**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS B-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:18	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:19
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06940**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:21	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:12
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06941**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:30	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:13
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06942**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:32	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:15
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06943**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:53	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:24
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06944**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:56	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:25
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06945**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	18:59	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:27
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06946**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:02	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:25
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06947**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PCC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:05	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:36
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06948**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_SS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:08	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:57
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06949**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:17	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:34
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06950**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_SS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:20	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 12:35
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06951**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **Beanery_SS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:23	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:04
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06952**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:26	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:05
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06953**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_FS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:38	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:07
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06954**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:41	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:08
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06955**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:43	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:10
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06956**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:46	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:12
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06957**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:49	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:19
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06958**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	19:58	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:13
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06959**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:01	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:15
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06960**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:04	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:15
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06961**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **ML_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:07	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:17
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06962**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:10	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:19
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06963**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:31	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:20
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06964**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:34	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:21
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06965**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:37	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:34
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06966**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_IM 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:46	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:23
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06967**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:49	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:24
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06968**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:52	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:24
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06969**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:55	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:26
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06970**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	20:58	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:27
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06971**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:01	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:28
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06972**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_HS 3-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:04	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:29
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06973**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **G_IM 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:15	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:43
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06974**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:18	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:45
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06975**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:27	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:47
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06976**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:30	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:48
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06977**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:33	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:01
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06978**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:36	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:00
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06979**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:39	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:59
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06980**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:42	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 09:50
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06981**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PRCC_FLS 2-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:45	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:29
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06982**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	21:48	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:33
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06983**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:15	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:35
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06984**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:18	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:36
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06985**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:21	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:37
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06986**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:24	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:38
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06987**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_HS 1-4**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:27	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:39
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06988**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **VADC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:30	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:15
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06989**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PS_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:33	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:10
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06990**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PS_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:36	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:17
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06991**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PS_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:39	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:17
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06992**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PS_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:42	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:58
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06993**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	22:59	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:57
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06994**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:02	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 10:55
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06995**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	1	ug/L	1	15	EPA 200.8 rev5.4	23:05	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:22
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06996**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 1-3**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:08	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:20
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06997**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 1-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:11	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:01
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06998**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------


Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:14	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:03
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK06999**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:17	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:06
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07000**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:20	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:07
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07001**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 2-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:23	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:12
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07002**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 3-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:32	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 11:10
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07003**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **RTC_HS 3-2**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
--------------	--------	-------	----	-----	------------------	---------------	---------------

Drinking Water Metal Analysis

Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:53	08/05/2019
-----------------------------	--------------	------	---	----	------------------	-------	------------

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:34
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07004**

Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **PPO_FS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:56	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:55
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07005**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **WEC_HS 1-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	23:59	08/05/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:50
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**
 BA Sample ID **CK07006**


Project Name: **201907 MCC Main Campus**
 Project Number:
 Sample ID: **WEC_HS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:02	08/06/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 8/13/2019



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 MDNRE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 07/30/2019 13:53
 Submit Date/Time: 07/30/2019 15:00
 Report Date: 08/13/2019

Mott Community College
 1401 East Court St.
 Flint, MI 48503

BA Project # **60076**

Project Name: **201907 MCC Main Campus**

BA Sample ID **CK07007**

Project Number:


Sample ID: **WEC_FS 2-1**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	00:05	08/06/2019

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

Date 8/13/2019