

Potable water testing for lead was done on, April 3, 2019 at the following drinking fountains, and sinks at Mott Community College site locations. Samples were collected by MCC's Risk Management personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.
pB = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected
 EPA maximum allowable level for lead - 15 ppb
 MCC cautionary level for potable water = 5 ppb, at which time remedial action will be taken
 OOO - Out of Order

Location	Sample ID	4/3/2019	Response
Lapeer			
Drinking Fountains			
Large Commons, C320	LAPR_HS 1-1	ND	
Small Commons, MiWorks!	LAPR_HS 1-2	ND	
Sinks			
Staff Breakroom, LAPR C314	LAPR_FS 1-1	ND	
LAPR C317	LAPR_S 1-2	1	
Staff Kitchenette, LAPR B206	LAPR_S 1-3	1	
Continuing Education, B218	LAPR_S 1-4	2	
Michigan Works!, A101	LAPR_S 1-5	2	
Northern Tier Center			
Drinking Fountains			
Commons, Drinking Fountain 1 (Left)	NTC_DF 1-1	2	
Commons, Drinking Fountain 2 (Right)	NTC_DF 1-2	ND	
Sinks			
Main Office Kitchenette, NTC 105	NTC_S 1-1	ND	
Servery, NTC 113A	NTC_S 1-2	ND	
Great Lakes Baptist			
Sinks			
Kitchenette	GLBC_FS 1-1	ND	
Hispanic Community Center			
Sink			
Main Building Kitchen	HTC_FS 1-1		No access
Food Pantry Sink	HTC_FP_FS 1-1		No access
Drinking Fountain			
Food Pantry - Left	HTC_FP_DF 1-1		No access
Food Pantry - Right	HTC_FP_DF 1-2		No access

Disability Network

Hydration Stations		
Main Entry	DN_HS 1-1	ND
Sink		
Kitchenette	DN_FS 1-1	ND

Southern Lakes Branch Campus

Drinking Fountains		
Hallway by 1104, West Entry	SLB_DF 1-1	ND
Within 1104	SLB_DF 1-2	~ Removed from Service
Hallway by 1004	SLB_DF 1-3	2
Hallway by 1304	SLB_DF 1-4	1
Drinking Fountain by 1104, East Entry	SLB_DF 1-5	ND
Academy Fountain, building C	SLC_DF 1-1	ND
Sinks		
Staff Breakroom, 1104A	SLB_FS 1-1	ND
PTA/OTA 1012, Kitchenette	SLB_S 1-2	ND
PTA/OTA 1016	SLB_S 1-3	ND
PTA/OTA 1502	SLB_FS 1-4	ND
PTA/OTA 1014 Left	SLB_S 1-5	1
PTA/OTA 1014 Right	SLB_S 1-6	4
PTA/OTA Classroom 1011	SLB_S 1-7	2

Livingston MTEC

Hydration Stations		
Hallway by Restrooms, Left unit	LIV_DF 1-1	ND
Hallway by Restrooms, Right unit	LIV_DF 1-2	ND
Highbay, Left Unit	LIV_DF 1-3	ND
Highbay, Right Unit	LIV_DF 1-4	ND
Sinks		
Staff Kitchenette	LIV_S 1-1	ND
Certified Aide Classroom 105, Left sink	LIV_S 1-2	ND
Certified Aide Classroom 105, Right sink	LIV_S 1-3	ND

Early Childhood Center Temporary Facility

Sinks		
ECD Blue Room	ECD Blue Room	ND
ECD Green Room	ECD Green Room	ND
ECD Red Room	ECD Red Room	ND
ECD Yellow Room	ECD Yellow Room	ND