

Potable water testing for lead was done on, January 3 & 17, 2018 at the following drinking fountains, and sinks at Mott Community College site locations. Samples were collected by MCC's Risk Management personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.

pB = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected

EPA maximum allowable level for lead - 15 ppb

MCC cautionary level for potable water = 5 ppb, at which time remedial action will be taken

OOO - Out of Order

Location	Sample ID	1/3/2019	1/17/2019	Response
Lapeer				
Drinking Fountains				
Large Commons, C320	LAPR_HS 1-1	ND		
Small Commons, MIWorks!	LAPR_HS 1-2	ND		
Sinks				
Staff Breakroom, LAPR C314	LAPR_FS 1-1	ND		
LAPR C317	LAPR_S 1-2	2		
Staff Kitchenette, LAPR B206	LAPR_S 1-3	3		
Continuing Education, B218	LAPR_S 1-4	1		
Michigan Works!, A101	LAPR_S 1-5	2		
Northern Tier Center				
Drinking Fountains				
Commons, Drinking Fountain 1 (Left)	NTC_DF 1-1	ND		
Commons, Drinking Fountain 2 (Right)	NTC_DF 1-2	ND		
Sinks				
Main Office Kitchenette, NTC 105	NTC_S 1-1	ND		
Servery, NTC 113A	NTC_S 1-2	ND		
Great Lakes Baptist				
Sinks				
Kitchenette	GLBC_FS 1-1	ND		
Hispanic Community Center				
Sink				
Main Building Kitchen	HTC_FS 1-1		ND	
Food Pantry Sink	HTC_FP_FS 1-1		ND	
Drinking Fountain				
Food Pantry - Left	HTC_FP_DF 1-1		2	
Food Pantry - Right	HTC_FP_DF 1-2		ND	

Disability Network

Hydration Stations			
Main Entry	DN_HS 1-1	ND	
Sink			
Kitchenette	DN_FS 1-1	ND	

Southern Lakes Branch Campus

Drinking Fountains			
Hallway by 1104, West Entry	SLB_DF 1-1	ND	
Within 1104	SLB_DF 1-2	~	Removed from Service
Hallway by 1004	SLB_DF 1-3	2	
Hallway by 1304	SLB_DF 1-4	ND	
Drinking Fountain by 1104, East Entry	SLB_DF 1-5	ND	
Academy Fountain, building C	SLC_DF 1-1	ND	

Sinks			
Staff Breakroom, 1104A	SLB_FS 1-1	ND	
PTA/OTA 1012, Kitchenette	SLB_S 1-2	ND	
PTA/OTA 1016	SLB_S 1-3	3	
PTA/OTA 1502	SLB_FS 1-4	ND	
PTA/OTA 1014 Left	SLB_S 1-5	1	
PTA/OTA 1014 Right	SLB_S 1-6	3	
PTA/OTA Classroom 1011	SLB_S1-7	2	

Livingston MTEC

Hydration Stations			
Hallway by Restrooms, Left unit	LIV_DF 1-1	ND	
Hallway by Restrooms, Right unit	LIV_DF 1-2	ND	
Highbay, Left Unit	LIV_DF 1-3	ND	
Highbay, Right Unit	LIV_DF 1-4	ND	

Sinks			
Staff Kitchenette	LIV_S 1-1	ND	
Certified Aide Classroom 105, Left sink	LIV_S 1-2	ND	
Certified Aide Classroom 105, Right sink	LIV_S 1-3	2	

Family Life Center (Woodside Church)

Sinks		
ECD Literacy Room	ECD_111 FS 1-1	ND
ECD Main Office	ECD_110 FS 1-1	ND
ECD Director Office	ECD_109 FS 1-1	ND
ECD "Red Room"	ECD_108 FS 1-1	ND
ECD "Red Room"	ECD_106 FS 1-1	ND
ECD "Green Room"	ECD_107 FS 1-1	ND
ECD "Green Room"	ECD_105 FS 1-1	ND
ECD Storage	ECD_103 FS 1-1	ND
ECD "Yellow Room"	ECD_104 FS 1-1	ND
ECD "Yellow Room"	ECD_102 FS 1-1	ND
ECD Resource Room	ECD_101 S 1-1	ND
Hydration Stations		
ECD Hydration Station	ECD_HS 1-1	ND