

Potable water testing for lead was done on, June 18, 2019 at all hydrations station locations, filtered sinks, and ice machines at Mott Community College. Showers were also tested at Ballenger Field House and Durham Wellness and Physical Education Center. Samples were collected by MCC's Risk Management personnel and tested at Brighton Analytical, Inc., Brighton Michigan in accordance with EPA Method 200.8 rev5.4.

Sample ID = MCC's tracking number for physical assets.

pb = chemical symbol for lead; **ppb** = parts per billion; **ND** = Not Detected

EPA maximum allowable level for lead - 15 ppb

MCC cautionary level for potable water = 5 ppb, at which time remedial action will be taken

* These units have two bubblers but only one water source. All water runs through the same filter, requiring only one sample

** Name Change - Sample ID's previously started with "D"

OOO - Out of Order

| Location | Sample ID | 6/18/19 | Response |
|--|------------|---------|-------------------------------|
| Ballenger Field House | | | |
| Hydration Stations | | | |
| Mens' Locker Room | ~ | ~ | Removed during renovation |
| Hallway to Men's Locker Room | BFH_HS 1-2 | ND | |
| Main Entry, South Side | BFH_HS 1-3 | ~ | Under Construction |
| Main Entry, North Side | BFH_HS 1-4 | ~ | Under Construction |
| Hallway to Women's Locker Room | BFH_HS 1-5 | ~ | Water off due to construction |
| Sinks | | | |
| Athletic Concessions, RM 122 | BFH_FS 1-1 | ~ | Under construction |
| Women's Hospitality Room, RM 1208 | BFH_FS 1-2 | ~ | Water off due to construction |
| Blamer Hospitality Room, RM 1306 | BFH_FS 1-3 | ND | |
| Blamer Hospitality Room, RM 1306 | BFH_FS 1-4 | ND | |
| Training Room, RM 1511 | BFH_S 1-5 | ND | |
| Athletics Concessions Hand Sink, RM122 | BFH_FS 1-6 | ~ | Under construction |
| Ice Makers | | | |
| Athletics Concessions, RM 122 | BFH_IM 1-1 | ~ | Under construction |
| Training Room, RM 1511 | BFH_IM 1-2 | ND | |

Ballenger Field House (Cont)

Showers

| | | | |
|---|----------------|----|-------------------------------|
| Unisex Shower, Men's Side RM 1103 | BFH_SHWR 1-1 | 1 | |
| Unisex Shower, Men's Side RM 1105 | BFH_SHWR 1-2 | ND | |
| Unisex Shower, Women's Side RM 1204 | BFH_SHWR 1-3 | ~ | Water off due to construction |
| Unisex Shower, Women's Side RM 1206 | BFH_SHWR 1-4 | ~ | Water off due to construction |
| Lady Bear Shower RM 1410A, Stall 1 (ADA) | BFH_SHWR 1-5.1 | ~ | Water off due to construction |
| Lady Bear Shower RM 1410A, Stall 2 | BFH_SHWR 1-5.2 | ~ | Water off due to construction |
| Lady Bear Shower RM 1410A, Stall 3 | BFH_SHWR 1-5.3 | ~ | Water off due to construction |
| Visiting Woman's Shower RM 1804A, Stall 1 (ADA) | BFH_SHWR 1-6.1 | ~ | No access due to construction |
| Visiting Woman's Shower RM 1804A, Stall 2 | BFH_SHWR 1-6.2 | ~ | No access due to construction |
| Visiting Woman's Shower RM 1804A, Stall 3 | BFH_SHWR 1-6.3 | ~ | No access due to construction |
| Visiting Men's Shower RM 1509A, Stall 1 (ADA) | BFH_SHWR 1-7.1 | ND | |
| Visiting Men's Shower RM 1509A, Stall 2 | BFH_SHWR 1-7.2 | 1 | |
| Visiting Men's Shower RM 1509A, Stall 3 | BFH_SHWR 1-7.3 | ND | |
| Men's Bear Den Shower RM 1503B, Stall 1 | BFH_SHWR 1-8.1 | ND | |
| Men's Bear Den Shower RM 1503B, Stall 2 | BFH_SHWR 1-8.2 | ND | |
| Men's Bear Den Shower RM 1503B, Stall 3 (ADA) | BFH_SHWR 1-8.3 | ND | |

Durham Wellness & Physical Education Center**

Hydration Stations

| | | | |
|--------------------------------------|-------------|----|--|
| * Main Floor South, Strength/Cardio | DRHM_HS 1-1 | ND | |
| * Main Floor North, Functional 1 & 2 | DRHM_HS 1-2 | ND | |

Showers

| | | | |
|------------------------------------|-----------------|----|--|
| Men's Shower Room, Stall 1 | DRHM_SHWR 1-1.1 | 1 | |
| Men's Shower Room, Stall 2 | DRHM_SHWR 1-1.2 | 1 | |
| Men's Shower Room, Stall 3 (ADA) | DRHM_SHWR1-1.3 | ND | |
| Women's Shower Room, Stall 1 (ADA) | DRHM_SHWR 1-2.1 | 1 | |
| Women's Shower Room, Stall 2 | DRHM_SHWR 1-2.2 | ND | |
| Women's Shower Room, Stall 3 | DRHM_SHWR 1-2.3 | 1 | |

Curtice Mott Complex

Hydration Stations

| | | |
|--|-----------|----|
| Administration Hallway by 1019 | CM_HS 1-1 | ND |
| 1st Flr, West Hallway by 1104 | CM_HS 1-2 | ND |
| 1st Flr, West Hallway by 1112 | CM_HS 1-3 | ND |
| 1st Flr, West Hallway by 1120 | CM_HS 1-4 | ND |
| 1st Flr, East Hallway by 1132 | CM_HS 1-5 | ND |
| 1st Flr, East Hallway by 1146 | CM_HS 1-6 | ND |
| 1st Flr, North East Hallway by Vending | CM_HS 1-7 | ND |
| 1st Flr, South East Hallway by 1307 | CM_HS 1-8 | ND |
| 2nd Flr, South West Hallway by 2001 | CM_HS 2-1 | ND |
| 2nd Flr, South West Hallway by 2018 | CM_HS 2-2 | ND |
| 2nd Flr, South West Hallway by 2033 | CM_HS 2-3 | ND |
| 2nd Flr, West Hallway by 2118 | CM_HS 2-4 | ND |
| 2nd Flr, East Hallway by 2138 | CM_HS 2-5 | ND |
| 2nd Flr, East Hallway by Vending | CM_HS 2-6 | ND |

Sinks

| | | |
|---|-----------|----|
| Admin Staff Lounge, CM 1004 | CM_FS 1-1 | ND |
| Presidential Coffee Bar, CM 1019 | CM_FS 1-2 | ND |
| Staff Lounge, CM 1113 | CM_FS 1-3 | ND |
| Custodial Lounge | CM_FS 1-4 | ND |
| Emergency Operations Center, CM 1143 | CM_FS 1-5 | ND |
| PS Health & Medical Services, CM 1146A | CM_FS 1-6 | ND |
| Computer Support Services Breakroom, CM 1208H | CM_FS 1-7 | ND |
| Printing/Shipping & Receiving Kitchen, CM 1309J | CM_S 1-8 | ND |
| E-Learning Office, CM 2124 | CM_FS 2-1 | 1 |
| Business Division, CM 2133E | CM_FS 2-2 | ND |
| Health Sciences Breakroom, CM 2313M | CM_FS 2-3 | ND |

Filtration Systems

| | | |
|---|---------------|----|
| Bistro Handsink, counter in sale area | Bistro_SS 1-1 | ND |
| Bistro Handsink, wall by SW exit to service | Bistro_SS 1-2 | ND |
| Bistro, Handsink SW wall, wash area | Bistro_SS 1-3 | ND |
| Bistro, Triple Compartment, Faucet 1 | Bistro_SS 1-4 | ND |
| Bistro, Handsink, SE wall by storage | Bistro_SS 1-5 | ND |
| Bistro, Spray Sink (Not used for food prep) | Bistro_SS 1-6 | ND |
| Bistro, Ice Maker | Bistro_IM 1-1 | ND |

Gorman

Hydration Stations

| | | |
|------------------------------------|----------|----|
| 1st Flr, Left Unit (while facing) | G_HS 1-1 | ND |
| 1st Flr, Center Unit | G_HS 1-2 | ND |
| 1st Flr, Right Unit (while facing) | G_HS 1-3 | ND |
| 2nd Flr, Left Unit (while facing) | G_HS 2-1 | ND |
| 2nd Flr, Center Unit | G_HS 2-2 | ND |
| 2nd Flr, Right Unit (while facing) | G_HS 2-3 | ND |
| 3rd Flr, Left Unit (while facing) | G_HS 3-1 | ND |
| 3rd Flr, Center Unit | G_HS 3-2 | ND |
| 3rd Flr, Right Unit (while facing) | G_HS 3-3 | ND |

Sinks

| | | |
|---|----------|----|
| Science & Math Division Office Breakroom, G 1001A | G_FS 1-1 | ND |
|---|----------|----|

Ice Makers

| | | |
|---------------------------|----------|----|
| Biology, G 1008A | G_IM 1-1 | ND |
| Physical Sciences, G 3106 | G_IM 3-1 | ND |

Mott Library

Hydration Stations

| | | |
|---------------------------|-----------|----|
| * 1st Floor by 1016 | ML_HS 1-1 | ND |
| * 1st Floor Events Center | ML_HS 1-2 | ND |
| * 2nd Floor by Elevator | ML_HS 2-1 | ND |
| * 2nd Floor by 2202 | ML_HS 2-2 | ND |
| * 3rd Floor by 3003 | ML_HS 3-1 | ND |
| * 3rd Floor by 3202 | ML_HS 3-2 | ND |

Sinks

| | | |
|---|-----------|----|
| Library Staff Breakroom, ML 1018 | ML_FS 1-1 | ND |
| Events Center Servery, ML 1212A | ML_FS 1-2 | ND |
| Center for Teaching & Learning, ML 3104 | ML_FS 3-1 | ND |

Ice Makers

| | | |
|---------------------------------|-----------|----|
| Events Center Servery, ML 1212A | ML_IM 1-1 | ND |
|---------------------------------|-----------|----|

Mott Memorial Building

Hydration Stations

| | | |
|-------------------------------|-------------|----|
| Terrace Level, Media Services | MMB_HS SB-1 | ND |
| 1st Floor by 1127 | MMB_HS 1-1 | ND |
| 1st Floor Main Entrance | MMB_HS 1-2 | ND |
| 1st Floor by 1025 | MMB_HS 1-3 | ND |
| 1st Floor Music Wing | MMB_HS 1-4 | ND |
| 2nd Floor by 2129 | MMB_HS 2-1 | ND |
| 2nd Floor by 2002 | MMB_HS 2-2 | ND |
| 2nd Floor by 2011 | MMB_HS 2-3 | ND |
| 2nd Floor by 2019 | MMB_HS 2-4 | ND |
| 2nd Floor Dental Wing | MMB_HS 2-5 | ND |

Sinks

| | | |
|--------------------------------------|-------------|----|
| Educational Media Services, MMB B010 | MMB_FS SB-1 | ND |
| Early Education Classroom, MMB 2011 | MMB_FS 2-1 | ND |
| Dental Staff Breakroom, MMB 2036A | MMB_FS 2-2 | ND |

Prahl College Center

Hydration Stations

| | | |
|------------------------------|------------|----|
| * Lower Level | PCC_HS B-1 | ND |
| * 1st Floor Information Desk | PCC_HS 1-1 | ND |
| * 2nd Floor | PCC_HS 2-1 | ND |

Sinks

| | | |
|---|------------|----|
| Culinary Arts Bakery, PCC B280 | PCC_FS B-1 | ND |
| Culinary, SC in Prep PCC B282 | PCC_FS B-2 | ND |
| Culinary Arts DC by Freezer, faucet 1 | PCC_FS B-3 | ND |
| Culinary Arts DC by Freezer, faucet 2 | PCC_FS B-4 | ND |
| Genesee Room, PCC 1230 | PCC_FS 1-1 | ND |
| Veterans Resource Center, PCC 1240A | PCC_FS 1-2 | ND |
| Counseling & Student Development Breakroom, PCC 2030F | PCC_FS 2-1 | ND |
| Advising Breakroom, PCC 2060C | PCC_FS 2-2 | ND |
| Learning Center Breakroom, PCC 2280T | PCC_FS 2-3 | ND |

Ice MakerS

| | | | |
|----------------------------------|------------|----|------------------------------------|
| Culinary Arts Kitchen | PCC_IM B-1 | ~ | Removed from service, taken to CAI |
| Culinary Arts Servery, Applewood | PCC_IM 1-1 | ND | |

Filtration Systems

| | | | |
|------------------------------|----------------|-----|----------------|
| Beanery Handsink, sale area | Beanery_SS 1-1 | ND | |
| Beanery Ice Maker, sale area | Beanery_IM 1-1 | OOO | Out of service |
| Beanery Handsink, prep area | Beanery_SS1-2 | ND | |
| Beanery Wash Sink, prep area | Beanery_SS1-3 | ND | |

Pappas Presidential Conference Center

Sinks

| | | |
|-------------------------------|--------------|----|
| Main Powder Room_109 | PRCC_FLS 1-1 | ND |
| Small Powder Room_102 | PRCC_FLS 1-2 | ND |
| Kitchen Sink_Double | PRCC_FS 1-1 | ND |
| Kitchen Sink_Single | PRCC_FS 1-2 | ND |
| Foundation/Community Outreach | PRCC_FLS 2-1 | ND |
| Ruth Mott VIP Suite | PRCC_FLS 2-2 | ND |
| MKTG & Development | PRCC_FLS 2-3 | ND |
| Communications & Advancement | PRCC_FLS 2-4 | ND |

Public Safety

Hydration Stations

| | | |
|------------------------|-----------|----|
| Vehicle Bay | PS_HS 1-1 | ND |
| Administrative Hallway | PS_HS 2-1 | ND |

Sinks

| | | |
|--|-----------|----|
| Public Safety Staff Breakroom, PS 1003 | PS_FS 1-1 | ND |
| Public Safety Conference Room, PS 2016 | PS_FS 2-1 | ND |

Physical Plant Operations

Sinks

| | | |
|---------|------------|----|
| Kitchen | PPO_FS 1-1 | ND |
|---------|------------|----|

Regional Technology Center

Hydrations Stations

| | | |
|---------------------|------------|----|
| * 1st Floor by 1201 | RTC_HS 1-1 | ND |
| * 1st Floor by 1404 | RTC_HS 1-2 | ND |
| * 1st Floor by 1009 | RTC_HS 1-3 | ND |
| * 2nd Floor by 2201 | RTC_HS 2-1 | ND |
| * 2nd Floor by 2404 | RTC_HS 2-2 | ND |
| * 3rd Floor by 3201 | RTC_HS 3-1 | ND |
| * 3rd Floor by 3604 | RTC_HS 3-2 | ND |

Sinks

| | | |
|--|------------|----|
| Student Services Communications, RTC 1302 | RTC_FS 1-1 | ND |
| Community Classroom/Meeting, RTC 1403 | RTC_FS 1-2 | ND |
| RTC Events Served, RTC 1502 | RTC_FS 1-3 | ND |
| Technology Division Kitchenette, RTC 2700G | RTC_FS 2-1 | ND |

Visual Arts and Design Center

Hydration Stations

| | | |
|--|-------------|----|
| North Hallway by Vending | VADC_HS 1-1 | ND |
| South Hallway between restrooms, Left | VADC_HS 1-2 | ND |
| South Hallway between restrooms, Right | VADC_HS 1-3 | ND |
| South Hallway by 1118B | VADC_HS 1-4 | ND |

Sinks

| | | |
|--|-------------|----|
| Visual Arts & Design Center Breakroom, VADC 100B | VADC_FS 1-1 | ND |
| Transition's Salon, VADC 119A | VADC_FS 1-2 | ND |
| Graphic Design Lab, VADC 103 | VADC_FS 1-3 | ND |

Workforce Education Center (Garfield G. Wagner)

Hydration Stations

| | | |
|----------------------------|------------|----|
| 1st Floor Information Desk | WEC_HS 1-1 | ND |
| 2nd Floor by Restrooms | WEC_HS 2-1 | ND |

Sinks

| | | |
|--|------------|----|
| Workforce Education Center Kitchenette, WAG 2003 | WEC_FS 2-1 | ND |
|--|------------|----|